

# VERIFICATION OF CONFORMITY

Certificate No.: IN-SH-CP-5627-20118

Applicant: **Coronet Group Suzhou Co., Ltd.**  
Address: **Ascendas Xinsu Square, 5 Xinghan Street, Suzhou, Jiangsu, China**  
Manufacturer: **Q/IN-SH-CP-5627-20109**  
Address: **Q/IN-SH-CP-5627-20109, China**

It has been verified that  
Product(s): **Ringlock Scaffold**  
Specifications: **are shown in second page**

are submitted by the applicant to the testing of the product in accordance with **the applicant's requirements**

The product is deemed to be in conformity with the requirements of **Uniformly Distributed Load Test** according to **EN 12811-1:2003 – clause 6.2.2.2**, **Concentrated Load on Area 200mmX200mm** according to **EN 12811-1:2003 – clause 6.2.2.3** on basis of the test report of **SHIN2006035527CM**.

This verification is valid from **23 July 2020** until **22 July 2023**

**Issue 1. Verified since 23 July 2020**

Authorised by

scan to see the report



IN-SH-CP-5627-20118

**Bob Wang**  
Deputy Director  
Industrial Services

SGS-CSTC Standards Technical Services Co., Ltd. Shanghai Branch

The 3<sup>rd</sup> Building, No. 69, Block 1159, Kangqiao East Road, Pudong Dist., Shanghai, China 201319

t +86 (0)21 6119 6300 f +86 (0)21 6119 1853

email CN.CONSTProdcert@sgs.com web www.sgs.com



**Disclaimer:** Neither SGS-CSTC, any of its affiliated SGS sister organizations nor the SGS Group can be held responsible for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

# VERIFICATION OF CONFORMITY

Certificate No.: IN-SH-CP-5627-20118


..continued..

Specifications are shown as following:

Reference Number	Sample Name
RV66	Ringlock Standard 2.0m
RH307	Ringlock Ledger 3.07m
RH257	Ringlock Ledger 2.57m
RH207	Ringlock Ledger 2.07m
RH157	Ringlock Ledger 1.57m
RH140	Ringlock Ledger 1.40m
RH109	Ringlock Ledger 1.09m
RH073	Ringlock Ledger 0.73m
ROSP32073	Ringlock Steel Plank 3.07x0.32m
ROSP32257	Ringlock Steel Plank 2.57x0.32m
ROSP32207	Ringlock Steel Plank 2.07x0.32m
ROSP32157	Ringlock Steel Plank 1.57x0.32m
ROSP32140	Ringlock Steel Plank 1.40x0.32m
ROSP32109	Ringlock Steel Plank 1.09x0.32m
ROSP32073	Ringlock Steel Plank 0.73x0.32m
CSJB600	Ringlock Base Jack 600mm
RSC-L	Ringlock Base Collar 310mm

Issue 1. Verified since **23 July 2020**

Authorised by



**Bob Wang**  
Deputy Director  
Industrial Services

# VERIFICATION OF CONFORMITY

Certificate No.: IN-SH-CP-5627-20118

..continued..

Results of examinations are as following:

Test Items	Test Method	Requirements	Results	Verdict
Uniformly Distributed Load Test	EN 12811-1:2003 – clause 6.2.2.2	EN 12811-1:2003 The working area shall be capable of supporting the uniformly distributed load	See Test Report SHIN2006035527CM	Pass
Concentrated Load on Area 200mmX200mm	EN 12811-1:2003 – clause 6.2.2.3	See Test Report SHIN2006035527CM	See Test Report SHIN2006035527CM	Pass

**Statement:** Unless otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

**Issue 1.** Verified since **23 July 2020**

Authorised by



**Bob Wang**  
Deputy Director  
Industrial Services